

Industrial gas detector, with replaceable sensor cartridge



Video




User's Manual



Certification

TS282

- Power supply: 12÷24 Vdc
- IP Rating: IP65
- No. 1 linear 4÷20 mA current output
- No. 3 LED shows the working conditions (red: alarm; green: normal; yellow: fault)
- Terminals plug-in polarized type



Code	Gas detected	Cartridge replacement	Measuring range	Calibration cylinder	Average time in clean air	Price	Technology
TS282KM	Metano - Natural gas	ZSK01/IP	0÷20% LFL	B0200	5 anni/years		
TS282KG	GPL - LPG	ZSK01/IP	0÷20% LFL	B0200	5 anni/years		
TS282KI	Idrogeno - Hydrogen	ZSK02/IP	0÷20% LFL	B0200	5 anni/years		
TS282KB	Benzina - Petrol	ZSKB/IP	0÷20% LFL	B0200	5 anni/years		
TS282PM	Metano - Natural gas	ZSP/IP	0÷100% LFL	B0200	5 anni/years		
TS282PG	Gpl - LPG	ZSP/IP	0÷100% LFL	B0200	5 anni/years		
TS282PI	Idrogeno - Hydrogen	ZSP/IP	0÷100% LFL	B0200	5 anni/years		
TS282PB	Benzina - Petrol	ZSP/IP	0÷100% LFL	B0200	5 anni/years		
TS282PX	Vedi tabella 1 - See Table 1	ZSP/IP	0÷100% LFL	B0200	5 anni/years		
TS282EA	Ammoniaca - Ammonia	ZSEA/IP	0÷300 ppm	B0501	2 anni/years		
TS282EA-H	Ammoniaca - Ammonia	ZSEA-H/IP	0÷300 ppm	B0501	2 anni/years		
TS282EC-S	Ossido di carbonio - Carbon monoxide	ZSEC/IP	0÷300 ppm	B0210	3 anni/years		
TS282EC-H	Ossido di carbonio - Carbon monoxide	ZSEC-H/IP	0÷300 ppm	B0210	2 anni/years		
TS282EH	Idr. solforato - Hydrogen sulphide	ZSEH/IP	0÷100 ppm	B0420	2 anni/years		
TS282ECL	Cloro - Chlorine	ZSECL/IP	0÷10 ppm	on request	2 anni/years		
TS282EHCL	Acido cloridrico - Hydrogen chloride	ZSEHCL/IP	0÷10 ppm	B0477	2 anni/years		
TS282EHCN	Acido cianidrico - Hydrogen cyanide	ZSEHCN/IP	0÷10 ppm	B0479	2 anni/years		
TS282EN	Ossido di azoto - Nitric oxide	ZSEN/IP	0÷100 ppm	B0472	2 anni/years		
TS282EN2	Biossido di azoto - Nitrogen dioxide	ZSEN2/IP	0÷30 ppm	on request	2 anni/years		
TS282ES	Anidride solforosa - Sulfur dioxide	ZSES/IP	0÷20 ppm	B0468	2 anni/years		
TS282EO	Ossigeno - Oxygen	ZSEO/IP	0÷25% Vol.	B0416	2 anni/years		